

## **360W SINGLE OUTPUT**







All dimensions in mm

Single Phase Input

FFATURES

- Built In Transient protector & EMI filter
- Protection against short circuit, overload ,overvoltage &
- Power OK indication, terminations, output set control & rating details on front
  - 100% full load burn in tested


PEATURES	Overtemperature (80°C)  Low ripple & noise  Forced Cooling (Internal fan)  Low cost  High reliability  Compact						
ISOLATION	Input – Output : 2KVAC, 1 minute Input – Earth : 2KVAC, 1 minute Output – Earth : 0.5KVAC, 1 minute						
EFFICIENCY	70 ~ 75%						
O/P VOLTAGE ADJUSTMENT	+/- 10% of nominal output voltage						
OVERLOAD PROTECTION	105% ~ 130% of rated load						
LINE & LOAD REGULATION	Better than 0.5%						
HOLD UP TIME	> 20ms at rated input voltage and load						
OPERATING AMBIENT	0 ~ 50°C, 95% RH						
STORAGE AMBIENT	-20°C to 85°C						
SAFETY STANDARD	Design refers to EN60950-1						
EMC STANDARD	Design refers to EN55022, EN55024						
TERMINATIONS	Screw type, for 2.5mm sq. wire						
MOUNTING	35 mm DIN rail						
WEIGHT	1400 grams						

	1100 grano								
		NOMINAL INPUT : 230VAC/DC		NOMINAL INPUT : 110VAC/DC					
	INPUT VOLTAGE	AC	DC	AC	DC	OUTPUT	RIPPLE & NOISE	OVERVOLTAGE PROTECTION	
	INPUT RANGE	180 ~ 270V	200 ~ 360V	90 ~ 130V	100 ~ 160V				
	I/P FREQUENCY	47 ~ 63Hz	ı	47 ~ 63Hz	_				
	I/P CURRENT (max)	3.5A @230V	2A @230V	7A @110V	4A @110V				
	INRUSH CURRENT	32A @230V	23A @230V	16A @110V	11A @110V				
		G31-3	360-12 G32		860-12	12V : 30A	< 120mV	< 16V	
	ORDER CODE	G31-360-24		G32-360-24		24V : 15A	< 240mV	< 30V	
		G31-360-36		G32-360-36		36V : 10A	< 350mV	< 45V	

- - 1. All parameters measured at nominal input, rated load and 25°C of ambient temperature unless otherwise specified.

    2. Ripple & noise are measured at 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1 uf & 100uf parallel capacitor.
  - 3. The power supply is intended to be installed as a component inside the enclosure of final equipment. The final equipment must be re-confirmed that it still meets the EMC directives.

    4. These units are designed for mounting on horizontal DIN rail. Ensure clearance of minimum 35mm from adjacent components for proper ventilation.



Unit No:G-5/6, B Wing, Plot K-3, Udyog Bhavan No:2, Anand Nagar MIDC, Ambernath(E) 421506, MH, India. Boardlines: +91-251-2620417, 2620427 Cell: +91-9820362980 Email: shavison@shavison.com www.shavison.com



Page 1 of 1

Date: 7<sup>th</sup> Feb 2018 Doc No: 21500.pdf Rev. 4